




instruction manual

AXB-VOL3

Three-Channel Volume Control



AXlink Bus Controllers

AMX Limited Warranty and Disclaimer

AMX Corporation warrants its products to be free of defects in material and workmanship under normal use for three (3) years from the date of purchase from AMX Corporation, with the following exceptions:

- Electroluminescent and LCD Control Panels are warranted for three (3) years, except for the display and touch overlay components that are warranted for a period of one (1) year.
- Disk drive mechanisms, pan/tilt heads, power supplies, MX Series products, and KC Series products are warranted for a period of one (1) year.
- Unless otherwise specified, OEM and custom products are warranted for a period of one (1) year.
- Software is warranted for a period of ninety (90) days.
- Batteries and incandescent lamps are not covered under the warranty.

This warranty extends only to products purchased directly from AMX Corporation or an Authorized AMX Dealer.

AMX Corporation is not liable for any damages caused by its products or for the failure of its products to perform. This includes any lost profits, lost savings, incidental damages, or consequential damages. AMX Corporation is not liable for any claim made by a third party or by an AMX Dealer for a third party.

This limitation of liability applies whether damages are sought, or a claim is made, under this warranty or as a tort claim (including negligence and strict product liability), a contract claim, or any other claim. This limitation of liability cannot be waived or amended by any person. This limitation of liability will be effective even if AMX Corporation or an authorized representative of AMX Corporation has been advised of the possibility of any such damages. This limitation of liability, however, will not apply to claims for personal injury.

Some states do not allow a limitation of how long an implied warranty last. Some states do not allow the limitation or exclusion of incidental or consequential damages for consumer products. In such states, the limitation or exclusion of the Limited Warranty may not apply. This Limited Warranty gives the owner specific legal rights. The owner may also have other rights that vary from state to state. The owner is advised to consult applicable state laws for full determination of rights.

EXCEPT AS EXPRESSLY SET FORTH IN THIS WARRANTY, AMX CORPORATION MAKES NO OTHER WARRANTIES, EXPRESSED OR IMPLIED, INCLUDING ANY IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. AMX CORPORATION EXPRESSLY DISCLAIMS ALL WARRANTIES NOT STATED IN THIS LIMITED WARRANTY. ANY IMPLIED WARRANTIES THAT MAY BE IMPOSED BY LAW ARE LIMITED TO THE TERMS OF THIS LIMITED WARRANTY.

Table of Contents

| | |
|--|----------|
| Product Information | 1 |
| Specifications | 1 |
| Installation | 3 |
| DIP Switch Settings..... | 3 |
| Wiring | 3 |
| Preparing and connecting captive wires | 3 |
| Wiring guidelines..... | 3 |
| AXlink connector | 4 |
| Volume channels 1 - 3 connectors..... | 4 |
| Programming | 5 |
| Channel Settings Commands..... | 5 |
| Levels | 5 |
| Send_Commands..... | 6 |

Product Information

The AXB-VOL3 Three-Channel Volume Control provides three audio volume control channels. Each line-level channel, opto-isolated from system ground, can be configured for balanced or unbalanced line operation. The AXB-VOL3 is programmable for 128 steps of audio level, audio mute, variable ramp speed and level presets. The AXB-VOL3 connects to Access control systems using the 4-wire AXlink data/power bus; it can be used for remote or rack mount applications.




FIG. 1 AXB-VOL3 front and rear panel

Specifications

| AXB-VOL3 Specifications | |
|---|---|
| Three line-level audio control channels: | |
| Line operation: | Balanced or unbalanced |
| Audio ground: | Audio ground opto-isolated from system ground. |
| Nominal input level: | -10 to +4 dBm. |
| Max. input/output level: | +16 dBm. |
| Volume level resolution: | 128 volume level steps ($\pm .5$ dB per step). |
| Attenuation: | 72 dB at full attenuation (mute). |
| Total Harmonic Distortion: | THD = <.008% |
| Frequency Response | 20 Hz to 20 kHz +/- 1 dB |


| AXB-VOL3 Specifications (Cont.) | |
|--|---|
| Front Panel Components: | |
| AXlink LED | AXlink LED (green and blinks to indicate AXlink communication activity and power: <ul style="list-style-type: none"> • Full-Off indicates no power is being received or the controller is not functioning properly. • One blink per second indicates power is active and AXlink communication is functioning. • Full-On indicates there is no AXlink control or activity, but power is On. |
| Device DIP Switch | An 8-position DIP switch used to set the AXlink device number for the AXB-VOL3. |
| Channel LEDs | Red channel LEDs 1 - 3. The LEDs individually light indicating a change in channel levels. |
| Rear Panel Components: | |
| AXlink connector | 4-pin, captive wire connector, receives power and information via the AXlink and AXlink Central Controller. |
| Volume Channel connectors | 6-pin, captive wire connectors that control audio level, audio mute, variable ramp speed and level presets of up to 3 devices. |
| Enclosure | Metal with black matte finish |
| Dimensions (HWD) | 1.51" x 5.55" x 5.45" (3.84 cm x 14.10 cm x 13.84 cm) |
| Weight | 1.1 lb (0.499 kg) |
| AXlink Power | 12 VDC @ 230 mA |

Installation

DIP Switch Settings

Use the device DIP switch to set the AXB-VOL3 AXlink device number. You can set it as one of 255 devices in an Access control system. Set the device number with the total of all ON (down) switches. As an example, the DIP switch below defines Device 128.

| Device DIP Switch Settings | | | | | | | | |
|----------------------------|---|---|---|---|----|----|----|-----|
| Position | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 |
| Value | 1 | 2 | 4 | 8 | 16 | 32 | 64 | 128 |



The device number takes effect only upon power-up. If you later change the device number, remove and reconnect the AXlink connector to enter the new device number into memory. AMX standard device numbers are assigned as follows:

- Cards are 1 through 25.
- Boxes are 96 through 127.
- Panels are 128 through 255.

The AXB-PCCOM emulates a touch panel when set in the panel range.

Wiring

Preparing and connecting captive wires

1. Strip 0.25 inch of wire insulation off all wires.
2. Insert each wire into the appropriate opening on the connector according to the wiring diagrams and connector types described in this section.
3. Tighten the screws to secure the wires. Do not tighten the screws excessively; doing so may strip the threads and damage the connector.

Wiring guidelines

The interface requires a 12 VDC power to operate properly. The interface uses a PSN2.8 power supply. The Central Controller supplies power via the AXlink cable or external 12 VDC power supply. The maximum wiring distance between the Central Controller and interface is determined by power consumption, supplied voltage, and the wire gauge used for the cable. The table below lists wire sizes and maximum lengths allowable between the VOL3 and Central Controller. The maximum wiring lengths for using AXlink power are based on a minimum of 13.5 volts available at the Central Controller's power supply.

| Wiring Guidelines at 230 mA | |
|-----------------------------|------------------------|
| Wire Size | Maximum Wiring Length |
| 18 AWG | 510.31 feet (155.54 m) |
| 20 AWG | 371.29 feet (113.17 m) |
| 22 AWG | 201.29 feet (61.35 m) |
| 24 AWG | 126.88 feet (38.67 m) |

AXlink connector

Install the AXlink data/power bus wiring as shown in FIG. 2.




FIG. 2 AXlink data/power connections

Volume channels 1 - 3 connectors

Volume channels 1 - 3 can be wired for unbalanced or balanced line operation, as shown in FIG. 3.

Optional 600 ohm resistor can be added for impedance matching, if required




FIG. 3 Volume Channels 1 - 3 Connector wiring diagrams

Programming

The following sections list Access programming commands used with the AXB-VOL3.

Channel Settings Commands

Use the AXB-VOL3 channel settings listed for ramp up, ramp down and mute operations..

| AXB-VOL3 Channel Setting Commands | | | |
|-----------------------------------|------------------------------|---------|-----------------------|
| Channel | Description | Channel | Description |
| 1 | Ramps channels 1 and 2 up. | 7 | Ramps channel 2 up. |
| 2 | Ramps channels 1 and 2 down. | 8 | Ramps channel 2 down. |
| 3 | Mutes channels 1 and 2. | 9 | Mutes channel 2. |
| 4 | Ramps channel 1 up. | 10 | Ramps channel 3 up. |
| 5 | Ramps channel 1 down. | 11 | Ramps channel 3 down. |
| 6 | Mutes channel 1. | 12 | Mutes channel 3. |



NOTE

Ramping a volume channel while the mute channel is on will NOT automatically turn off the mute channel (will not restore) but the ramping will still occur and the volume change will be noticed when the mute channel is turned off. For setting ramp rates and presets, see SEND_COMMAND programming instructions below. For reading current volume levels and displaying bargraphs see CREATE_LEVEL and SEND_LEVEL programming instructions. Volume channels 1 through 3 use levels 1 to 3 respectively.

When controlling levels, such as with an active bargraph, there is no LED indication of volume changes.

Levels

- 1 = Output #1
- 2 = Output #2
- 3 = Output #3

Send_Commands

System Send_Commands are stored in the Access Control System.

| AXB-VOL3 Send_Commands | |
|------------------------|---|
| PLT | <p>Ramps specified channel(s) from current level to a specified preset level or percentage at the current rate or optionally in a specified amount of time.</p> <p>Syntax: <code>SEND_COMMAND VOL, 'P<output channel 0-3>L<level 0-255 0-100%>[T<Time 0-255 in tenth second increments>]'</code></p> <p>Variables: Output Channel = Channel numbers 1, 2 or 3. Output channel 0 = both channels 1 and 2. Level = Level number (0-255) or percentage (0-100 percent). Level 0 is lowest volume (same as mute) and 255 or 100% is maximum volume. Time = Optional ramp time (0-255) in tenths of a second.</p> <p>Example 1: <code>SEND_COMMAND VOL, 'P0L50%'</code> Ramps both channels to 50% mid level volume at the current ramp rate.</p> <p>Example 2: <code>SEND_COMMAND VOL, 'P1L255T20'</code> Ramps channel 1 to highest level volume in 2 seconds.</p> |
| PR | <p>Sets the ramp rate of the specified channel(s) where the time is the time to ramp the full range both down to up and up to down or optionally just down to up or just up to down.</p> <p>Syntax: <code>SEND_COMMAND VOL, 'P<output channel 0-3>R<ramp rate 0-255 in tenth seconds>[U D]'</code></p> <p>Variables: Output Channel = Channel numbers 1, 2 or 3. Output channel 0 = both channels 1 and 2. Ramp Rate = Sets ramp rate (1-255) for channel commands in tenth second increments. U = Optional character sets rate for ramp up. D = Optional character sets rate for ramp down.</p> <p>Example 1: <code>SEND_COMMAND VOL, 'P0R50'</code> Sets ramp rate of channels 1 and 2 to 5 seconds full range from down to up and up to down.</p> <p>Example 2: <code>SEND_COMMAND VOL, 'P3R50D'</code> Sets ramp rate of channel 3 to 5 seconds full range from up to down only.</p> |

AXB-VOL3 Send_Commands (Cont.)**PP**

Syntax:

`SEND_COMMAND VOL, 'P<Channel> = P<Channel>'`

Variable:

Channel = Enter channel number.

Examples:

`SEND_COMMAND VOL, 'P1 = P2'`

Sets channel 1 level to the same as channel 2.

`SEND_COMMAND VOL, 'P1 = P3'`

Sets channel 1 level to the same as channel 3.

`SEND_COMMAND VOL, 'P2 = P1'`

Sets channel 2 level to the same as channel 1.

`SEND_COMMAND VOL, 'P2 = P3'`

Sets channel 2 level to the same as channel 3.

`SEND_COMMAND VOL, 'P3 = P1'`

Sets channel 3 level to the same as channel 1.

`SEND_COMMAND VOL, 'P3 = P2'`

Sets channel 3 level to the same as channel 2.

Note: You cannot use 'P0' with these commands.



AMX reserves the right to alter specifications without notice at any time.

brussels • dallas • los angeles • mexico city • philadelphia • shanghai • singapore • tampa • toronto* • york
3000 research drive, richardson, TX 75082 USA • 469.624.8000 • 800.222.0193 • fax 469.624.7153 • technical support 800.932.6993

032-004-1024 12/04 ©2004 AMX Corporation. All rights reserved. AMX, the AMX logo, the building icon, the home icon, and the light bulb icon are all trademarks of AMX Corporation. AMX reserves the right to alter specifications without notice at any time. *In Canada doing business as Panja Inc.